



# DETROIT RADIANT PRODUCTS

## RTVP-8 Installation Sheet

The installation of this venting MUST conform with local building codes or, in the absence of local codes, with the National Fuel Gas Code, ANSI-Z223.1-1999 (NFPA54 current edition).

A 1 in. clearance (air space) to combustable material must be maintained when using Simpson Dura-Vent round B-Vent, regardless of the diameter.



\*Item not included in the kit.



Printed in U.S.A.

© 2005 Detroit Radiant Products Co.  
21400 Hoover Rd., Warren, MI 48089  
T. (586) 756-0950 F. (586) 756-2626  
www.reverberray.com  
Form# LSH RTVP-8-4/05

