

Tube Heater Accessory Sheet

8" Rooftop Vent Package Assembly Diagram

The installation of this venting MUST conform with local building codes or, in the absence of local codes, with the National Fuel Gas Code, ANSI-Z223.1-1999 (NFPA54 current edition).


A 1 in. clearance (air space) to combustible material must be maintained when using Simpson Dura-Vent round B-Vent, regardless of the diameter.

RTVP-8 Kit Contents

- (1) Drafhood Connector (8GVC)
- (1) Adjustable Rooftop Flashing (ARF-8)
- (1) 8" Vent Cap (8GVDC)
- (1) 8" Firestop (8GVFS)
- (1) 8" Storm Collar (8GVSC)
- (2) 8"x8"x6" Sheet Metal 'Y'
- (2) 4"x6"x4" Sheet Metal 'Y' (YSM)
- (2) High Temperature Sealant (RTV-106)

NOTE: 8" B-Vent (BVP-8) must be ordered separately. B-Vent only offered as a 60" section.


Figure 1 • Kit Contents



Tube Heater Accessory Sheet

8" Rooftop Vent Package Assembly Diagram

Figure 2 • Rooftop Vent Requirements



*Item not included in the kit.