

# DETROIT RADIANT PRODUCTS

## LS & LD Baffle Installation Sheet

Insert assembled baffles with the HEAT baffle preceding the PRES-  
SURE baffles (fig. 1). Allow for  
turbulator fins, so that the key hole is  
inserted first. All baffles must be  
placed vertically in the last radiant  
tube/heat exchanger (fig. 2).

If the heater is installed with a U or  
Elbow fitting all baffle must still re-  
main. There may be some instances

where the baffle will be cut into two sections. Place as much baffle as possible downstream  
of the U or Elbow and the remainder of the baffle just before the U or Elbow fitting.

